## **TOOLBOX TALK #37**

### Vital GRP

### **Vehicle Fuels**

**Prepare:** Quiet location? No distractions? Talk aids ready?

**Reason:** The amount of plant operating on most sites will

result in the use of large quantities of fuel, all of

which create hazards.

**Why:** By being aware of the risks, the chance of an

accident occurring can be reduced or eliminated.

**Outline:** This talk will cover the hazards created by

different fuels and the precautions necessary.

NOTES



#### **Petrol**

- Usually, only small plant such as disc cutters and chainsaws now run on petrol.
- Petrol fumes are highly flammable only refuel plant in well-ventilated areas.
- Up to 20 litres of petrol only should be stored on site.
- Petrol must only be stored in purpose designed containers – 10 litres maximum.
- No smoking in areas where petrol is stored or decanted.

#### **Diesel**

- There are no storage restrictions for diesel fuel.
- Protective gloves should be worn when handling diesel oil because skin contact can result in irritation leading to dermatitis and infection.
- As an oil, spilt diesel will cause a slipping hazard on hard surfaces.
- Diesel oil should be stored in metal cans which should be kept in a lockable store.

## Q: How do you reduce the chance of diesel oil spillage when refuelling plant?

### **Liquefied Petroleum Gas (LPG)**

- LPG is used mainly as a fuel for small plant vehicles such as dumpers and forklift trucks.
- Cylinders are of special construction and designed to be mounted on their side.
- Cylinder connectors and other unions have a left-hand thread.
- LPG vapour is heavier than air; leaks will accumulate at floor level if not allowed to disperse.

For more information
Call: +44(0) 1206 396446
Email: <a href="mailto:sales@vitalgrp.co.uk">sales@vitalgrp.co.uk</a>
vitalgrp.co.uk

# **TOOLBOX TALK #37**

## Vital GRP

## **Vehicle Fuels**

		NOTES
•	Always use the correct size of spanner for tightening or loosening connections; hand tight connections will allow leaks.	
	What arrangement should be made for the orage of LPG cylinders?	
Q: How can you prevent the accumulation of leaking LPG at floor level?		
•	LPG vapour is highly flammable and must be kept away from sources of heat, naked flames and sparks (including electric sparks).	
	What type of fire extinguisher should you have r hot works using LPG?	
No	ote to supervisor:	
CO	ow inform your workforce of the mpany policy regarding the safe storage of vehicle els.	
Do you have any questions for me?		

**Sources**: Overview: Storing petrol safely - HSE Fire and explosion - HSE Safe use of petrol in garages - HSE End of life vehicle industry - HSE